Illinois
Environmental
Protection Agency

Division of Public Water Supplies
2200 Churchill Road
Springfield, Illinois 62706

Groundwater Quality Protection Program

Round Lake
FACILITY NUMBER 0971500
WELL SITE SURVEY REPORT

Division of Public Water Supplies

[redacted]

IEPA/PWS/93-099

GROUNDWATER QUALITY PROTECTION PROGRAM:

Round Lake
FACILITY NUMBER 0971500
WELL SITE SURVEY REPORT

Presented by:

Division of Public Water Supplies

Published by:

Illinois Environmental Protection Agency

Springfield, Illinois

April 1994

TABLE OF CONTENTS

INTRODUCTION

This report has been prepared by the Illinois Environmental Protection Agency (Agency) pursuant to Section 17.1 of the Illinois Environmental Protection Act (Act). The report summarizes information about your facility and samples collected and analyzed from your well(s). The well site survey provides an inventory of the area around the well(s) to help increase your awareness of potential hazards to the groundwater utilized by your facility. This information and technical data will assist you in developing and implementing local groundwater protection measures authorized by the Act.

FACILITY DESCRIPTION AND GEOLOGIC PROFILE OF WELL SITES

Round Lake has three public water supply wells. The facility produces 343,000 gallons per day to an estimated population of 3550. See Table I for a description of each well. The wells utilize a shallow bedrock and a deep bedrock (for well no. 3) aquifer overlain by uniform, relatively impermeable silty or clayey till at least 50 feet thick. Permeability is the ability of a soil or sediment to transmit fluids. A detailed description and geologic profile is found in the Facility wells Report (Appendix D).

TABLE 1

Well I.D.	Setback Min. (Ft.)	Setback Max. (Ft.)	Status	Capacity (gpm) (MGD)	Specific Capacity (gpm/ft)	Treatment	Aquifer	Well Depth (Ft.)	Well Logs Avail.
Well #1 (20298)	200		A	140.2 0.202	NA	Cl	Shallow Bedrock	350	No
Well #2 (20299)	200		A	249.8 0.360	NA	Cl	Shallow Bedrock	359	Yes
Well #3 (20300)	200		A	399.0 0.576	NA	Cl	Deep Bedrock	1241	Yes

A=Active; I=Inactive; SB=Standby

GROUNDWATER SAMPLING/MONITORING HISTORY

The public water supply wells no. 1, no. 2, and no. 3 were sampled as part of the Statewide Groundwater Monitoring Network on January 7, 1987 and August 6, 1985 (for well no. 2). The samples were analyzed for volatile organic and aromatic chemicals (VOC/VOA) and inorganic chemcials (IOC). The VOC/VOA analyses performed detected no quantifiable levels of organic chemicals in the wells. The IOC analyses performed found the water from the wells to meet all general use guidelines.

SURVEY METHODS AND PROCEDURES

The detailed well site survey consists of an aerial photographic map and inventory sheets (Appendix B-C), that relate information about potential sources, routes and possible problem sites to your water supply well(s). The location of potential sources, routes, possible problem sites, water supply wells, minimum setback zones, and 1,000 foot survey area are all displayed on the aerial photographic map.

The first page of each survey consists of a summary description and geologic profile for each well. The second and following pages of the survey inventory units within and bordering a 1,500 foot radius of the wellhead. A unit is defined as any device, mechanism, equipment, or area (exclusive of land utilized for agricultural production). The Agency five-digit well number is associated with a unit or map code, and then classified. The classification codes relate to definitions of potential contamination sources and routes as defined in the Illinois Groundwater Protection Act (see Groundwater Primer pages 18-19). The distance and direction of the unit from the wellhead is also indicated.

Survey Results and Findings:

The well site survey of Round Lake was conducted on June 29, 1993 by Laurie Moyer, Environmental Protection Specialist from the Agency's Rockford Regional Office. The following describes the results and findings for Round Lake.

Round Lake Well #1 (20298)

The survey area is urban consisting of commercial/industrial businesses. The well is located off Rt. 134. There are three visible potential sources, routes, or possible problem sites within the minimum setback zone (200 feet). These sites are Arkin Hardware (map code 1) located 100 feet southwest of the well, Molidor's Standard Service & Car Wash (map code 3) located 100 feet northwest of the well, and Chain-o-Lakes (map code 4) located 50 feet north of the well. Four potential source or possible problem site is located outside the minimum setback zone but within the survey area of the well (1500 feet). These sites are Round Lake Fire Department (map code 2) located 400 feet west of the well, A Tire Country Service (map code 5) located 725 feet northwest of the well, Kurz Machine and Manufacturing (map code 6) located 1000 feet northwest of the well, and One Hour Service Dry Cleaning (map code 8) located 1475 feet northwest of the well.

Round Lake Well #2 (20299)
The survey area is urban consisting of commercial/industrial businesses. The well is located off Cedar Lake Rd. There are no visible potential sources, routes, or possible problem sites within the minimum setback zone (200 feet). Ten potential source or possible problem site is located outside the minimum setback zone but within the survey area of the well (1500 feet). These sites are Arkin Hardware (map code 1) located 1250 feet southeast of the well, Round Lake Fire Department (map code 2) located 1150 feet south of the well, Molidor's Standard Service & Car Wash (map code 3) located 1150 feet southeast of the well, Chain-o-Lakes Lumber (map code 4) located 1100 feet southeast of the well, A Tire County Service (map code 5) located 400 feet southeast of the well, Kurz Machine and Manufacturing (map code 6) located 225 feet southeast of the well, Classy Chassis (map code 7) located 675 feet southwest of the well, One Hour Service Dry Cleaning (map code 8) located 350 feet north of the well, John MaGee Jr. High School (map code 9) located 800 feet north of the well, and The Grieve Corp. (map code 10) located 900 feet northwest of the well.

Round Lake Well #3 (20300)
The survey area is rural consisting of moderate density residential housing and farmland. The well is located off Nippersink Road. There are no visible potential sources, routes, or possible problem sites within the survey (200 feet) or located outside the minimum setback zone but within the survey (1500 feet).

SUMMARY

The well site survey conducted indicates that there are potential sources/sites that could pose a hazaed to groundwater utilized by the Round Lake public water wells.

- Two sites with below ground fuel storage: Molidor's Standard Service & Car Wash and A Tire Country Services (also a small quantity generator).

- Several other sites including Arkin Hardware, Round Lake Fire Department, Chain-o-Lakes Lumber, Kurz Machine & Manufacturing, Classy Chassis, One Hour Dry Cleaning, John MaGee Jr. High School and The Grieve Corp.

The Illinois Environmental Protection Act provides minimum protection zones for your wells. These minimum protection zones are regulated by the Agency. The Act also authorizes county and municipal officials the opportunity to provide maximum protection zones up to 1,000 feet. The responsibility for the control would then be assumed by the local officials through adoption of a maximum setback zone ordinance.

Maximum setback zones prohibit the siting of new potential primary sources of groundwater contamination. A maximum setback up to 1,000 feet could expand the regulatory coverage of certain existing and new activities. These controls could be implemented upon the adoption of proposed regulations by the Illinois Pollution Control Board.

RECOMMENDATIONS

The Agency strongly urges Round Lake to consider establishing a maximum setback zone ordinance for its wells. Maximum setback zones prohibit the siting of new potential primary sources of groundwater contamination up to 1000 feet from respective wellheads. Regulatory coverage of certain existing activities could be expanded upon adoption of proposed regulations currently before the Illinois Pollution Control Board. To aid you in the development of further regulatory coverage for your well supply, the Agency prepared a "Maximum Setback Zone Workbook" that provides detailed case studies of how to establish maximum setback zones. This text and further technical assistance is readily available form the Agency and the Illinois State Water Survey.

Local governments are also encouraged to consider conducting groundwater protection needs assessments. Any county or municipality having a population less than 25,000 or 5,000 persons respectively, may request the Agency to conduct a hazard review in lieu of a need's assessment. The Agency may issue an "advisory of groundwater contamination hazard" if a significant hazard to the public health or the environment exists.

TECHNICAL APPENDICES

APPENDIX A - Topographic Map of Round Lake (0971500) Well Site Locations



APPENDIX B
Aerial Photographic Map


APPENDIX B
Aerial Photographic Map
1500'
1000'
200'
CEDAR LAKE RD
RT. 134
HART RD.
SNIPPERSVILLE
20299
20298
1
2
3
4
5
6
7
8
9
10
NORTH
ROUND LAKE
0971500
1"=400'
S D E
3-1-94

Appendix B1 - WELL SITE SUMMARY DESCRIPTION AND GEOLOGIC PROFILE
Round Lake Well No. 1 (IEPA #20298)

SURVEYOR: Moyer
SURVEY DATE: 06-29-93
ADDRESS: Village of Round Lake
442 N. Cedar Lake Rd.
Round Lake, IL 60073

AGENCY WELL NO: 20298
WELL NAME & DESC: Well #1
TREATMENT APPLICATION POINT: 01
FACILITY NO. & NAME: 0971500 - Round Lake
FACILITY PHONE CONTACT: 708-546-0962

LOCATION: TWP, RNG, SECTION, 10 ACRE PLOT: 45N, 10E, 29, 4F
DISTANCE FROM CORNER: 1550N, 2400W
QUAD SHEET CODE & NAME: 008D - Grayslake
MIN. SETBACK: 200 feet
MAX. SETBACK:

SURFICIAL GEOLOGIC SUSCEPTIBILITY RATING: E- Uniform, relatively impermeable silty or clayey till at least 50 feet thick; no evidence of interbedded sand and gravel.
AGE OF WELL: 1912
WELL DEPTH: 350 feet
CASING DEPTH: 230
AQUIFER CODE: 5050 - Shallow Bedrock
MULTPLE AQUIFER (Y,N): No
SUMMARY DESCRIPTION OF 1,000' RADIUS AREA: The survey area is urban consisting of commerical/industrial businesses.

INTERVIEW(S) NAME-ADDRESS-AFFILIATION-TELEPHONE NO:

APPENDIX B1 - INVENTORY & SYNOPSIS OF UNIT(S) Round Lake Well No. 1 (IEPA #20298)

*CLASSF KEY

MIN. ZONE	OUTSIDE MIN. ZONE
PP = POTENTIAL PRIMARY	OP = POTENTIAL PRIMARY
PS = POTENTIAL SECONDARY	OS = POTENTIAL SECONDARY
RI = ROUTE	OR = ROUTE
CC = CERTIFIED	CC = CERTIFIED
XI = UNKNOWN	OX = UNKNOWN
CU = CLEANUP	CU = CLEANUP

WELL NO. - MAP CODE - CLASSF*: 20298-01
NAME & ADDRESS OF UNIT OWNER: Arkin Hardware, 319 W. Nippersink Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Hardware
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 100 feet southwest of the well

WELL NO. - MAP CODE - CLASSF*: 20298-02
NAME & ADDRESS OF UNIT OWNER: Round Lake Fire Department, 409 W. Nippersink Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Fire Department
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 400 feet west of the well

WELL NO. - MAP CODE - CLASSF*: 20298-03-PS
NAME & ADDRESS OF UNIT OWNER: Molidor's Standard Service & Car Wash, W. Nippersink Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Service Station & Car Wash, 3 registered underground storage tanks on site, OSFM #2-018131
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 100 feet northwest of the well

WELL NO. - MAP CODE - CLASSF*: 20298-04
NAME & ADDRESS OF UNIT OWNER: Chain-o-Lakes Lumber, 340 W. Railroad, Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Lumber yard
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 50 feet north of the well

WELL NO. - MAP CODE - CLASSF*: 20298-05-OS
NAME & ADDRESS OF UNIT OWNER: A Tire Country Service, 363 N. Cedar Lake Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Union 76 Gas Station and Goodyear Tire
Store, 3 registered underground storage tanks on site OSFM #2-006179
Small quanity generator
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 725 feet northwest of the well

APPENDIX B1 - INVENTORY & SYNOPSIS OF UNIT(S) Round Lake Well No. 1 (IEPA #20298)

*CLASSF KEY

MIN. ZONE	OUTSIDE MIN. ZONE
PP = POTENTIAL PRIMARY	OP = POTENTIAL PRIMARY
PS = POTENTIAL SECONDARY	OS = POTENTIAL SECONDARY
RI = ROUTE	OR = ROUTE
CC = CERTIFIED	CC = CERTIFIED
XI = UNKNOWN	OX = UNKNOWN
CU = CLEANUP	CU = CLEANUP

WELL NO. - MAP CODE - CLASSF*: 20298-06
NAME & ADDRESS OF UNIT OWNER: Kurz Machine and Manufacturing, 380 Cedar Lake Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Manufacture tools, dies, jigs, stamps, machine parts and general machining
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 1000 feet northwest of the well

WELL NO. - MAP CODE - CLASSF*: 20298-07
NAME & ADDRESS OF UNIT OWNER: Classy Chassis, 545 Railroad Ave., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Auto Repair
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 1600 feet northwest of the well

WELL NO. - MAP CODE - CLASSF*: 20298-08
NAME & ADDRESS OF UNIT OWNER: One Hour Service Dry Cleaning, 456 N. Cedar Lake Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Dry Cleaners
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 1475 feet northwest of the well

WELL NO. - MAP CODE - CLASSF*: 20298-09
NAME & ADDRESS OF UNIT OWNER: John MaGee Jr. High School, 500 N. Cedar Lake Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Jr. High School
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 2000 feet northwest of the well

WELL NO. - MAP CODE - CLASSF*: 20298-10
NAME & ADDRESS OF UNIT OWNER: The Grieve Corp., 500 Hart Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Manufacture industrial and laboratory ovens and furnaces
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 2150 feet northwest of the well

APPENDIX C
Aerial Photographic Map

APPENDIX B2 - INVENTORY & SYNOPSIS OF UNIT(S) Round Lake Well No. 2 (IEPA #20299)

SURVEYOR: Moyer
SURVEY DATE: 06-29-93
ADDRESS: Village of Round Lake
442 N. Cedar Lake Rd.
Round Lake, IL 60073

AGENCY WELL NO: 20299
WELL NAME & DESC: Well #2
TREATMENT APPLICATION POINT: 02
FACILITY NO. & NAME: 0971500 - Round Lake
FACILITY PHONE CONTACT: 708-546-0962

LOCATION: TWP, RNG, SECTION, 10 ACRE PLOT: 45N, 10E, 29, 5H
DISTANCE FROM CORNER: 600S, 2175E
QUAD SHEET CODE & NAME: 008D - Grayslake
MIN. SETBACK: 200 feet
MAX. SETBACK:

SURFICIAL GEOLOGIC SUSCEPTIBILITY RATING: E- Uniform, relatively impermeable silty or clayey till at least 50 feet thick; no evidence of interbedded sand and gravel.
AGE OF WELL: 1945
WELL DEPTH: 359 feet
CASING DEPTH: 226
AQUIFER CODE: 5050 - Shallow Bedrock
MULTPLE AQUIFER (Y,N): No
SUMMARY DESCRIPTION OF 1,000' RADIUS AREA: The survey area is urban consisting of commerical/industrial businesses.

INTERVIEW(S) NAME-ADDRESS-AFFILIATION-TELEPHONE NO:

APPENDIX B2 - INVENTORY & SYNOPSIS OF UNIT(S) Round Lake Well No. 2 (IEPA #20299)

*CLASSF KEY

MIN. ZONE	OUTSIDE MIN. ZONE
PP = POTENTIAL PRIMARY	OP = POTENTIAL PRIMARY
PS = POTENTIAL SECONDARY	OS = POTENTIAL SECONDARY
RI = ROUTE	OR = ROUTE
CC = CERTIFIED	CC = CERTIFIED
XI = UNKNOWN	OX = UNKNOWN
CU = CLEANUP	CU = CLEANUP

WELL NO. - MAP CODE - CLASSF*: 20299-01
NAME & ADDRESS OF UNIT OWNER: Arkin Hardware, 319 W. Nippersink Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Hardware
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 1250 feet southeast of the well

WELL NO. - MAP CODE - CLASSF*: 20299-02
NAME & ADDRESS OF UNIT OWNER: Round Lake Fire Department, 409 W. Nippersink Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Fire Department
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 1150 feet southeast of the well

WELL NO. - MAP CODE - CLASSF*: 20299-03-OS
NAME & ADDRESS OF UNIT OWNER: Molidor's Standard Service & Car Wash, W. Nippersink Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Service Station & Car Wash, 3 registered underground storage tanks on site, OSFM #2-018131
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 1150 feet southeast of the well

WELL NO. - MAP CODE - CLASSF*: 20299-04
NAME & ADDRESS OF UNIT OWNER: Chain-o-Lakes Lumber, 340 W. Railroad, Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Lumber yard
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 1100 feet southeast of the well

WELL NO. - MAP CODE - CLASSF*: 20299-05-OS
NAME & ADDRESS OF UNIT OWNER: A Tire Country Service, 363 N. Cedar Lake Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Union 76 Gas Station and Goodyear Tire
Store, 3 registered underground storage tanks on site OSFM #2-006179
Small quantity generator
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 400 feet southeast of the well

APPENDIX B2 - INVENTORY & SYNOPSIS OF UNIT(S) Round Lake Well No. 2 (IEPA #20299)

*CLASSF KEY

MIN. ZONE	OUTSIDE MIN. ZONE
PP = POTENTIAL PRIMARY	OP = POTENTIAL PRIMARY
PS = POTENTIAL SECONDARY	OS = POTENTIAL SECONDARY
RI = ROUTE	OR = ROUTE
CC = CERTIFIED	CC = CERTIFIED
XI = UNKNOWN	OX = UNKNOWN
CU = CLEANUP	CU = CLEANUP

WELL NO. - MAP CODE - CLASSF*: 20299-06
NAME & ADDRESS OF UNIT OWNER: Kurz Machine and Manufacturing, 380 Cedar Lake Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Manufacture tools, dies, jigs, stamps, machine parts and general machining
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 225 feet southeast of the well

WELL NO. - MAP CODE - CLASSF*: 20299-07
NAME & ADDRESS OF UNIT OWNER: Classy Chassis, 545 Railroad Ave., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Auto Repair
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 675 feet southwest of the well

WELL NO. - MAP CODE - CLASSF*: 20299-08
NAME & ADDRESS OF UNIT OWNER: One Hour Service Dry Cleaning, 456 N. Cedar Lake Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Dry Cleaners
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 350 feet north of the well

WELL NO. - MAP CODE - CLASSF*: 20299-09
NAME & ADDRESS OF UNIT OWNER: John MaGee Jr. High School, 500 N. Cedar Lake Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Jr. High School
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 800 feet north of the well

WELL NO. - MAP CODE - CLASSF*: 20299-10
NAME & ADDRESS OF UNIT OWNER: The Grieve Corp., 500 Hart Rd., Round Lake, IL 60073
DESCRIPTION AND COMMENTS: Manufacture industrial and laboratory ovens and furnaces
PRE OR POST (Y,N): Yes
DISTANCE AND DIRECTION: 900 feet northwest of the well

APPENDIX C

APPENDIX C1 - INVENTORY & SYNOPSIS OF UNIT(S) Round Lake Well No. 3 (IEPA #20300)

SURVEYOR: Moyer
SURVEY DATE: 06-29-93
ADDRESS: Village of Round Lake
442 N. Cedar Lake Rd.
Round Lake, IL 60073

AGENCY WELL NO: 20300
WELL NAME & DESC: Well #3
TREATMENT APPLICATION POINT: 03
FACILITY NO. & NAME: 0971500 - Round Lake
FACILITY PHONE CONTACT: 708-546-0962

LOCATION: TWP, RNG, SECTION, 10 ACRE PLOT: 45N, 10E, 30, 3D
DISTANCE FROM CORNER: 2600N, 1575W
QUAD SHEET CODE & NAME: 008D - Grayslake
MIN. SETBACK: 200 feet
MAX. SETBACK:

SURFICIAL GEOLOGIC SUSCEPTIBILITY RATING: E- Uniform, relatively impermeable silty or clayey till at least 50 feet thick; no evidence of interbedded sand and gravel.
AGE OF WELL: 1974
WELL DEPTH: 1241 feet
CASING DEPTH: 588
AQUIFER CODE: 6080 - Deep Bedrock
MULTPLE AQUIFER (Y,N): Yes
SUMMARY DESCRIPTION OF 1,000' RADIUS AREA: The survey area is urban consisting of moderate density residential housing and farmland.

INTERVIEW(S) NAME-ADDRESS-AFFILIATION-TELEPHONE NO:

APPENDIX C1 - INVENTORY & SYNOPSIS OF UNIT(S) Round Lake Well No. 3 (IEPA #20300)

*CLASSF KEY

MIN. ZONE	OUTSIDE MIN. ZONE
PP = POTENTIAL PRIMARY	OP = POTENTIAL PRIMARY
PS = POTENTIAL SECONDARY	OS = POTENTIAL SECONDARY
RI = ROUTE	OR = ROUTE
CC = CERTIFIED	CC = CERTIFIED
XI = UNKNOWN	OX = UNKNOWN

WELL NO. - MAP CODE - CLASSF*: 20300
NAME & ADDRESS OF UNIT OWNER:
DESCRIPTION AND COMMENTS: No visible potential sources, routes, or possible problem sites located in the survey area.
PRE OR POST (Y,N):
DISTANCE AND DIRECTION:

APPENDIX D

APPENDIX E

FACILITY: 0971500 ROUND LAKE

OWNER

JAMES LUMBER

PRESIDENT - MUNICIPAL BLDG

442 N CEDAR LAKE RD

ROUND LAKE IL 60073

OFFICIAL CUSTODIAN

WELL: 20296 WELL 1 REAR 322 RAILROAD AVE STATUS: ACTIVE BACKUP DRILLED DEPTH(FT): 350
LATITUDE: N42 21 14.0 LONGITUDE: W088 05 32.0 TWP: 45N RNG: 10E SEC: 29 PLOT: 4F

SUSCEPTIBILITY - LAND BURIAL: E SUSCEPTIBILITY - LAND SPREADING: D2 --- MINIMUM SETBACK(FT): 0200 ---
ALTITUDE (FT): 0.00 ALTITUDE METHOD CODE: - UNKNOWN
INTERVAL 1 - TYPE: 0 - N/A SCREEN MATL: 0 - NOT APPLICABLE DEPTH TO TOP (FT): 0.00 DEPTH TO BOT (FT): 0.00
INTERVAL 2 - TYPE: 0 - N/A SCREEN MATL: 0 - NOT APPLICABLE DEPTH TO TOP (FT): 0.00 DEPTH TO BOT (FT): 0.00
INTERVAL 3 - TYPE: 0 - N/A SCREEN MATL: 0 - NOT APPLICABLE DEPTH TO TOP (FT): 0.00 DEPTH TO BOT (FT): 0.00
AQUIFERS: DEVONIAN SILURIAN DOLOMITE

WELL: 20299 WELL 2 REAR 400 N CEDAR LAKE ROAD STATUS: ACTIVE BACKUP DRILLED DEPTH(FT): 359
LATITUDE: N42 21 23.0 LONGITUDE: W088 05 40.0 TWP: 45N RNG: 10E SEC: 29 PLOT: 5H

SUSCEPTIBILITY - LAND BURIAL: E SUSCEPTIBILITY - LAND SPREADING: D2 --- MINIMUM SETBACK(FT): 0200 ---
ALTITUDE (FT): 0.00 ALTITUDE METHOD CODE: - UNKNOWN
INTERVAL 1 - TYPE: 0 - N/A SCREEN MATL: 0 - NOT APPLICABLE DEPTH TO TOP (FT): 0.00 DEPTH TO BOT (FT): 0.00
INTERVAL 2 - TYPE: 0 - N/A SCREEN MATL: 0 - NOT APPLICABLE DEPTH TO TOP (FT): 0.00 DEPTH TO BOT (FT): 0.00
INTERVAL 3 - TYPE: 0 - N/A SCREEN MATL: 0 - NOT APPLICABLE DEPTH TO TOP (FT): 0.00 DEPTH TO BOT (FT): 0.00
AQUIFERS: DEVONIAN SILURIAN DOLOMITE

WELL: 20300 WELL 3 1049 NIPPERSINK RD W OF FAIRFIELD STATUS: ACTIVE BACKUP DRILLED DEPTH(FT): 1241
LATITUDE: N42 20 58.0 LONGITUDE: W088 06 46.0 TWP: 45N RNG: 10E SEC: 30 PLOT: 3D

SUSCEPTIBILITY - LAND BURIAL: E SUSCEPTIBILITY - LAND SPREADING: D2 --- MINIMUM SETBACK(FT): 0200 ---
ALTITUDE (FT): 0.00 ALTITUDE METHOD CODE: - UNKNOWN
INTERVAL 1 - TYPE: 0 - N/A SCREEN MATL: 0 - NOT APPLICABLE DEPTH TO TOP (FT): 0.00 DEPTH TO BOT (FT): 0.00
INTERVAL 2 - TYPE: 0 - N/A SCREEN MATL: 0 - NOT APPLICABLE DEPTH TO TOP (FT): 0.00 DEPTH TO BOT (FT): 0.00
INTERVAL 3 - TYPE: 0 - N/A SCREEN MATL: 0 - NOT APPLICABLE DEPTH TO TOP (FT): 0.00 DEPTH TO BOT (FT): 0.00
AQUIFERS: CINCINNATION SERIES CHAMPLAINIAN SERIES
CAMBRIAN SYSTEM EMINENCE-POTOSI
FRANCONIA IRONTON-GALESVILLE

FACILITY: 0971500 ROUND LAKE (CONTINUED)

SUSCEPTIBILITY CODES

LAND BURIAL: E = UNIFORM, RELATIVELY IMPERMEABLE SILTY OR CLAYEY TILL AT LEAST 50 FT THICK; NO EVIDENCE OF INTERBEDDED SAND AND GRAVEL.

LAND SPREADING: D2 = UNIFORM, RELATIVELY IMPERMEABLE SILTY OR CLAYEY TILL AT LEAST 20 FT THICK; NO EVIDENCE OF INTERBEDDED SAND AND GRAVEL.

APPENDIX F

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES
SELECTED SAMPLE EXPANDED REPORT

FACILITY: 0971500 ROUND LAKE STATUS: A PUBLIC: Y COMM: Y TYPE WATER:
TAP: STATUS:
RAW SRC: STATUS:

SAMPLE NO: 0003/200 LOCATION: ROUND LAKE COLL DATE: 03/19/90 DELIVERED BY: MAIL
SMPL TYPE: RAW COLLECTOR: D. ROWLEY LAB RCVD: 03/21/90 RECEIVED BY: PWD
SMPL PURP: 1-ROUTINE COMMENTS: LAB COMPL: 04/27/90 LAB SUPERVISOR: RPF
SMPL PROG: 2-CHEMICAL OBSRVATNS: SMPL PERIOD: 0000 FUND CODE: PW30

ANALYSIS ID	RSLT NO	STORET NO	DESCRIPTION	UNITS	RESULT	STANDARDS DRINK WTR	STANDARDS RAW WTR	TRIGGER LEVEL
100T000	001	00403	PH LABORATORY UNITS	UNITS	8.300			
101T000	001	00095	CONDUCTIVITY(EC)-LAB(UMHOS/CM @ 25 C	UM/CM	590.000			
102T000	001	70300	RESIDUE,TOTAL FILTERABLE @180 C,MG/L	MG/L	351.000			
103T000	001	00410	ALKALINITY,TOTAL MG/L AS CACO3	MG/L	171.000			
105T000	001	00900	HARDNESS,EDTA MG/L AS CACO3	MG/L	151.000			
107T000	001	00951	FLUORIDE,TOTAL MG/L AS F	MG/L	0.910	4.000		
108T000	001	00940	CHLORIDE,TOTAL MG/L AS CL	MG/L	2.400			
109T000	001	00945	SULFATE,TOTAL MG/L AS SO4	MG/L	131.000			
110T000	001	00630	NITRATE & NITRITE TOTAL MG/L AS N	MG/L	0.100 <	10.000		
111T000	001	00610	NITROGEN,AMMONIA TOTAL MG/L AS N	MG/L	0.380			
114T000	001	00956	SILICA,TOTAL MG/L AS SIO2	MG/L	13.000			
115T000	001	00720	CYANIDE,TOTAL MG/L AS CN	MG/L	0.005 <	0.200		
120T000	001	01002	ARSENIC,TOTAR RECOVERABLE UG/L AS AS	UG/L	1.000 <	50.000		
121T100	001	01051	LEAD,TOTAL RECOVERABLE UG/L AS PB	UG/L	5.000 <	50.000		
153T000	001	71900	MERCURY,TOTAL UG/L AS HG	UG/L	0.050 <	2.000		
155T000	001	01147	SELENIUM,TOTAL RECOVERABLE UG/L ASSE	UG/L	1.000 <	10.000		
177T100	001	00916	CALCIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP	MG/L	31.000			
177T100	002	00927	MAGNESIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP	MG/L	19.000			
177T100	003	00929	SODIUM,TOTAL RECOVERABLE MG/L AS NA ANAL BY ICP	MG/L	61.000			
177T100	004	00937	POTASSIUM,TOTAL RECOVERABLE MG/L AS K ANAL BY ICP	MG/L	0.790			
177T100	005	01105	ALUMINUM,TOTAL RECOVERABLE UG/L ASAL ANAL BY ICP	UG/L	50.000 <			
177T100	006	01007	BARIUM,TOTAL RECOVERABLE UG/L AS BA ANAL BY ICP	UG/L	13.000	1000.000		
177T100	007	01022	BORON,TOTAL RECOVERABLE UG/L AS B ANAL BY ICP	UG/L	468.000			
177T100	008	01012	BERYLLIUM,TOTAL RECOVERABLE UG/L AS BE ANAL BY ICP	UG/L	0.500 <			
177T100	009	01027	CADMIUM,TOTAL RECOVERABLE UG/L AS CD ANAL BY ICP	UG/L	3.000 <	10.000		
177T100	010	01034	CHROMIUM,TOTAL RECOVERABLE UG/L ASCR ANAL BY ICP	UG/L	5.000 <	50.000		
177T100	011	01042	COPPER,TOTAL RECOVERABLE UG/L AS CU ANAL BY ICP	UG/L	5.000 <	5000.000		
177T100	012	01037	COBALT,TOTAL RECOVERABLE UG/L AS CO ANAL BY ICP	UG/L	5.000 <			
177T100	013	01045	IRON,TOTAL RECOVERABLE, UG/L AS FEANAL BY ICP	UG/L	50.000 <	1000.000		
177T100	014	01055	MANGANESE,TOTAL RECOVERABLE UG/L AS MN ANAL BY ICP	UG/L	5.000 <	150.000		
177T100	015	01067	NICKEL,TOTAL RECOVERABLE UG/L AS NI ANAL BY ICP	UG/L	5.000 <			
177T100	016	01077	SILVER,TOTAL RECOVERABLE UG/L AS AG ANAL BY ICP	UG/L	3.000 <	50.000		
177T100	017	01082	STRONTIUM,TOTAL RECOVERABLE UG/L AS SR ANAL BY ICP	UG/L	968.000			
177T100	018	01087	VANADIUM,TOTAL RECOVERABLE UG/L ASV ANAL BY ICP	UG/L	5.000 <			
177T100	019	01092	ZINC,TOTAL RECOVERABLE UG/L AS ZN ANAL BY ICP	UG/L	50.000 <	5000.000		
177T100	020	82394	HARDNESS, CALC - MG/L	MG/L	156.000			

SAMPLE NO: 0003/300 LOCATION: ROUND LAKE COLL DATE: 03/19/90 DELIVERED BY: MAIL
SMPL TYPE: RAW COLLECTOR: D. ROWLEY LAB RCVD: 03/21/90 RECEIVED BY: PWD
SMPL PURP: 1-ROUTINE COMMENTS: LAB COMPL: 04/27/90 LAB SUPERVISOR: RPF

FACILITY: 0971500 ROUND LAKE *** CONTINUED ***

SMPL PROG: C-CHEMICAL OBSRVATNS: SMPL PERIOD: 03/90 FUND CODE: PW30

ANALYSIS ID	RSLT NO	STORET NO	DESCRIPTION	UNITS	RESULT	STANDARDS DRINK WTR	STANDARDS RAW WTR	TRIGGER LEVEL
100T000	001	00403	PH LABORATORY UNITS	UNITS	7.800			
101T000	001	00095	CONDUCTIVITY(EC)-LAB(UMHOS/CM @ 25 C	UM/CM	540.000			
102T000	001	70300	RESIDUE,TOTAL FILTERABLE @180 C,MG/L	MG/L	300.000			
103T000	001	00410	ALKALINITY,TOTAL MG/L AS CACO3	MG/L	259.000			
105T000	001	00900	HARDNESS,EDTA MG/L AS CACO3	MG/L	222.000			
107T000	001	00951	FLUORIDE,TOTAL MG/L AS F	MG/L	0.370	4.000		
108T000	001	00940	CHLORIDE,TOTAL MG/L AS CL	MG/L	10.000			
109T000	001	00945	SULFATE,TOTAL MG/L AS SO4	MG/L	21.000			
110T000	001	00630	NITRATE & NITRITE TOTAL MG/L AS N	MG/L	0.100 <	10.000		
111T000	001	00610	NITROGEN,AMMONIA TOTAL MG/L AS N	MG/L	0.100 <			
114T000	001	00956	SILICA,TOTAL MG/L AS SIO2	MG/L	7.400			
115T000	001	00720	CYANIDE,TOTAL MG/L AS CN	MG/L	0.005 <	0.200		
144T000	001	01002	ARSENIC,TOTAL RECOVERABLE UG/L AS AS	UG/L	1.000 <	50.000		
151T100	001	01051	LEAD,TOTAL RECOVERABLE UG/L AS PB	UG/L	5.000 <	50.000		
163T000	001	71900	MERCURY,TOTAL UG/L AS HG	UG/L	0.050 <	2.000		
165T000	001	01147	SELENIUM,TOTAL RECOVERABLE UG/L ASSE	UG/L	1.000 <	10.000		
177T100	001	00916	CALCIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP	MG/L	59.000			
177T100	002	00927	MAGNESIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP	MG/L	18.000			
177T100	003	00929	SODIUM,TOTAL RECOVERABLE MG/L AS NA ANAL BY ICP	MG/L	21.000			
177T100	004	00937	POTASSIUM,TOTAL RECOVERABLE MG/L AS K ANAL BY ICP	MG/L	11.000			
177T100	005	01105	ALUMINUM,TOTAL RECOVERABLE UG/L ASAL ANAL BY ICP	UG/L	256.000			
177T100	006	01007	BARIUM,TOTAL RECOVERABLE UG/L AS BA ANAL BY ICP	UG/L	1070.000	1000.000		
177T100	007	01022	BORON,TOTAL RECOVERABLE UG/L AS B ANAL BY ICP	UG/L	119.000			
177T100	008	01012	BERYLLIUM,TOTAL RECOVERABLE UG/L AS BE ANAL BY ICP	UG/L	0.500 <			
177T100	009	01027	CADMIUM,TOTAL RECOVERABLE UG/L AS CD ANAL BY ICB	UG/L	3.000 <	10.000		
177T100	010	01034	CHROMIUM,TOTAL RECOVERABLE UG/L ASCR ANAL BY ICB	UG/L	5.000 <	50.000		
177T100	011	01042	COPPER,TOTAL RECOVERABLE UG/L AS CU ANAL BY ICP	UG/L	5.000	5000.000		
177T100	012	01037	COBALT,TOTAL RECOVERABLE UG/L AS CO ANAL BY ICP	UG/L	5.000 <			
177T100	013	01045	IRON,TOTAL RECOVERABLE, UG/L AS FEANAL BY ICP	UG/L	50.000 <	1000.000		
177T100	014	01055	MANGANESE,TOTAL RECOVERABLE UG/L AS MN ANAL BY ICP	UG/L	26.000	150.000		
177T100	015	01067	NICKEL,TOTAL RECOVERABLE UG/L AS NI ANAL BY ICP	UG/L	5.000 <			
177T100	016	01077	SILVER,TOTAL RECOVERABLE UG/L AS AG ANAL BY ICP	UG/L	3.000 <	50.000		
177T100	017	01082	STRONTIUM,TOTAL RECOVERABLE UG/L AS SR ANAL BY ICP	UG/L	5396.000			
177T100	018	01087	VANADIUM,TOTAL RECOVERABLE UG/L ASV ANAL BY ICP	UG/L	5.000 <			
177T100	019	01092	ZINC,TOTAL RECOVERABLE UG/L AS ZN ANAL BY ICP	UG/L	50.000 <	5000.000		
177T100	020	32394	HARDNESS, CALC - MG/L	MG/L	224.000			

SAMPLE NO: B00397200 LOCATION: ROUND LAKE COLL DATE: 03/19/90 DELIVERED BY: MAIL
SMPL TYPE: RAW COLLECTOR: D ROWLEY LAB RCVD: 03/21/90 RECEIVED BY: PMD
SMPL PURP: 1-ROUTINE COMMENTS: LAB COMPL: 04/27/90 LAB SUPERVISOR: RPF
SMPL PROG: C-CHEMICAL OBSRVATNS: SMPL PERIOD: 03/90 FUND CODE: PW30

FACILITY: 0971000 ROUND LAKE *** CONTINUED ***

ANALYSIS ID	RSLT NO	STORET NO	STORET DESCRIPTION	UNITS	RESULT		STANDARDS DRINK WTR	STANDARDS RAW WTR	TRIGGER LEVEL
100T000	001	00400	PH LABORATORY UNITS	UNITS	8.200				
101T000	001	00095	CONDUCTIVITY(EC)-LAB(UMHOS/CM @ 25 C	UM/CM	580.000				
102T000	001	70300	RESIDUE,TOTAL FILTERABLE @180 C,MG/L	MG/L	351.000				
103T000	001	00410	ALKALINITY,TOTAL MG/L AS CACO3	MG/L	177.000				
105T000	001	00900	HARDNESS,EDTA MG/L AS CACO3	MG/L	156.000				
107T000	001	00951	FLUORIDE,TOTAL MG/L AS F	MG/L	0.900		4.000		
107T000	001	00940	CHLORIDE,TOTAL MG/L AS CL	MG/L	3.500				
109T000	001	00945	SULFATE,TOTAL MG/L AS SO4	MG/L	117.000				
110T000	001	00630	NITRATE & NITRITE TOTAL MG/L AS N	MG/L	0.100	<	10.000		
111T000	001	00610	NITROGEN,AMMONIA TOTAL MG/L AS N	MG/L	0.360				
114T000	001	00956	SILICA,TOTAL MG/L AS SIO2	MG/L	14.000				
115T000	001	00720	CYANIDE,TOTAL MG/L AS CN	MG/L	0.005	<	0.200		
144T000	001	01002	ARSENIC,TOTAR RECOVERABLE UG/L AS AS	UG/L	1.000	<	50.000		
151T100	001	01051	LEAD,TOTAL RECOVERABLE UG/L AS PB	UG/L	3.000	<	50.000		
153T000	001	71900	MERCURY,TOTAL UG/L AS HG	UG/L	0.050	<	2.000		
155T000	001	01147	SELENIUM,TOTAL RECOVERABLE UG/L ASSE	UG/L	1.000	<	10.000		
177T100	001	00916	CALCIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP	MG/L	31.000				
177T100	002	00927	MAGNESIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP	MG/L	21.000				
177T100	003	00929	SODIUM,TOTAL RECOVERABLE MG/L AS NA ANAL BY ICP	MG/L	38.000				
177T100	004	00937	POTASSIUM,TOTAL RECOVERABLE MG/L AS K ANAL BY ICP	MG/L	2.400				
177T100	005	01105	ALUMINUM,TOTAL RECOVERABLE UG/L ASAL ANAL BY ICP	UG/L	50.000	<			
177T100	006	01007	BARIUM,TOTAL RECOVERABLE UG/L AS BA ANAL BY ICP	UG/L	23.000		1000.000		
177T100	007	01022	BORON,TOTAL RECOVERABLE UG/L AS B ANAL BY ICP	UG/L	462.000				
177T100	008	01012	BERYLLIUM,TOTAL RECOVERABLE UG/L AS BE ANAL BY ICP	UG/L	0.500	<			
177T100	009	01027	CADMIUM,TOTAL RECOVERABLE UG/L AS CD ANAL BY ICB	UG/L	3.000	<	10.000		
177T100	010	01034	CHROMIUM,TOTAL RECOVERABLE UG/L ASCR ANAL BY ICB	UG/L	5.000	<	50.000		
177T100	011	01042	COPPER,TOTAL RECOVERABLE UG/L AS CU ANAL BY ICP	UG/L	5.000	<	5000.000		
177T100	012	01037	COBALT,TOTAL RECOVERABLE UG/L AS CO ANAL BY ICP	UG/L	5.000	<			
177T100	013	01045	IRON,TOTAL RECOVERABLE, UG/L AS FEANAL BY ICP	UG/L	195.000		1000.000		
177T100	014	01055	MANGANESE,TOTAL RECOVERABLE UG/L AS MN ANAL BY ICP	UG/L	7.000		150.000		
177T100	015	01067	NICKEL,TOTAL RECOVERABLF UG/L AS NI ANAL BY ICP	UG/L	6.000				
177T100	016	01077	SILVER,TOTAL RECOVERABLE UG/L AS AG ANAL BY ICP	UG/L	3.000	<	50.000		
177T100	017	01082	STRONTIUM,TOTAL RECOVERABLE UG/L AS SR ANAL BY ICP	UG/L	1314.000				
177T100	018	01087	VANADIUM,TOTAL RECOVERABLE UG/L ASV ANAL BY ICP	UG/L	5.000	<			
177T100	019	01092	ZINC,TOTAL RECOVERAELE UG/L AS ZN ANAL BY ICP	UG/L	50.000	<	5000.000		
177T100	020	82394	HARDNESS, CALC - MG/L	MG/L	161.000				

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES
SELECTED SAMPLE EXPANDED REPORT

FACILITY: 0971500 ROUND LAKE STATUS: A PUBLIC: Y COMM: Y TYPE WATER:
TAP: 01 WELL 1 STATUS: A
RAW SRCE: 20298 WELL 1 REAR 322 RAILROAD AVE STATUS: A

SAMPLE NO: Z004731 LOCATION: WELL COLL DATE: 01/07/87 DELIVERED BY:
SMPL TYPE: Raw COLLECTOR: IEPA SMPL COLLECTOR LAB RCVD: 00/00/00 RECEIVED BY:
SMPL PURP: 5-SPEC/OTHR COMMENTS: LAB COMPL: 00/00/00 LAB SUPERVISOR:
SMPL PROG: I-SWM INORG OBSRVATNS: SMPL PERIOD: 01/87 FUND CODE:

ANALYSIS ID	RSLT NO	STORET NO	DESCRIPTION	UNITS	RESULT	STANDARDS DRINK WTR	STANDARDS RAW WTR	TRIGGER LEVEL
0000001	001	00610	NITROGEN,AMMONIA TOTAL MG/L AS N		0.210			
0000001	002	00630	NITRATE & NITRITE TOTAL MG/L AS N		0.100	10.000		
0000001	003	00665	PHOSPHORUS, TOTAL MG/L AS P		0.010 <			
0000001	004	00720	CYANIDE,TOTAL MG/L AS CN		0.010 <	0.200		
0000001	005	00916	CALCIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP		29.000			
0000001	006	00927	MAGNESIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP		20.000			
0000001	007	00929	SODIUM,TOTAL RECOVERABLE MG/L AS NA ANAL BY ICP		62.000			
0000001	008	00937	POTASSIUM,TOTAL RECOVERABLE MG/L AS K ANAL BY ICP		1.000			
0000001	009	00940	CHLORIDE,TOTAL MG/L AS CL		2.200			
0000001	010	00945	SULFATE,TOTAL MG/L AS SO4		139.000			
0000001	011	00951	FLUORIDE,TOTAL MG/L AS F		1.000	4.000		
0000001	012	00956	SILICA,TOTAL MG/L AS SIO2		13.000			
0000001	013	00956	SILICA,TOTAL MG/L AS SIO2		13.000			
0000001	014	01002	ARSENIC,TOTAL RECOVERABLE UG/L AS AS		1.000 <	50.000		
0000001	015	01007	BARIUM,TOTAL RECOVERABLE UG/L AS BA ANAL BY ICP		7.000	1000.000		
0000001	016	01012	BERYLLIUM,TOTAL RECOVERABLE UG/L AS BE ANAL BY ICP		0.500 <			
0000001	017	01022	BORON,TOTAL RECOVERABLE UG/L AS B ANAL BY ICP		551.000			
0000001	018	01027	CADMIUM,TOTAL RECOVERABLE UG/L AS CD ANAL BY ICP		3.000 <	10.000		
0000001	019	01034	CHROMIUM,TOTAL RECOVERABLE UG/L AS CR ANAL BY ICP		5.000 <	50.000		
0000001	020	01037	COBALT,TOTAL RECOVERABLE UG/L AS CO ANAL BY ICP		5.000 <			
0000001	021	01042	COPPER,TOTAL RECOVERABLE UG/L AS CU ANAL BY ICP		5.000 <	5000.000		
0000001	022	01045	IRON,TOTAL RECOVERABLE UG/L AS FEANAL BY ICP		75.000	1000.000		
0000001	023	01051	LEAD,TOTAL RECOVERABLE UG/L AS PB		5.000 <	50.000		
0000001	024	01055	MANGANESE,TOTAL RECOVERABLE UG/L AS MN ANAL BY ICP		5.000 <	150.000		
0000001	025	01067	NICKEL,TOTAL RECOVERABLE UG/L AS NI ANAL BY ICP		5.000 <			
0000001	026	01077	SILVER,TOTAL RECOVERABLE UG/L AS AG ANAL BY ICP		3.000 <	50.000		
0000001	027	01082	STRONTIUM,TOTAL RECOVERABLE UG/L AS SR ANAL BY ICP		968.000			
0000001	028	01087	VANADIUM,TOTAL RECOVERABLE UG/L ASV ANAL BY ICP		5.000 <			
0000001	029	01092	ZINC,TOTAL RECOVERABLE UG/L AS ZN ANAL BY ICP		50.000 <	5000.000		
0000001	030	01105	ALUMINUM,TOTAL RECOVERABLE UG/L ASAL ANAL BY ICP		50.000 <			
0000001	031	01147	SELENIUM,TOTAL RECOVERABLE UG/L ASSE		1.000 <	10.000		
0000001	032	32730	PHENOLS, TOTAL RECOVERABLE UG/L		5.000 <			
0000001	033	70300	RESIDUE,TOTAL FILTERABLE @180 C,MG/L		533.000			
0000001	034	71900	MERCURY,TOTAL UG/L AS HG		0.050 <	2.000		
0000001	035	00059	FLOW (PUMPING) RATE GAL/MIN		145.000			
0000001	036	72004	FLOW (PUMPING) TIME PRIOR TO SAMPLING MIN		385.000			
0000001	037	90410			167.000			

SAMPLE NO: Z004730 LOCATION: WELL COLL DATE: 01/07/87 DELIVERED BY:
SMPL TYPE: RAW COLLECTOR: IEPA SMPL COLLECTOR LAB RCVD: 00/00/00 RECEIVED BY:

FACILITY: 0971500 ROUND LAKE *** CONTINUED ***

SMPL PURP: 5-SPEC/OTHR COMMENTS:
SMPL PROG: V-VOC OBSRVATNS:
LAB COMPL: 00/00/00 LAB SUPERVISOR:
SMPL PERIOD: 01/37 FUND CODE:

ANALYSIS ID	RSLT NO	STORET NO	DESCRIPTION	UNITS	RESULT	STANDARDS DRINK WTR	STANDARDS RAW WTR	TRIGGER LEVEL
0000001	001	32101	BROMODICHLOROMETHANE UG/L GC/MS		1.000 <			
0000001	002	32102	CARBON TETRACHLORIDE UG/L GC/MS		1.000 <	5.000		
0000001	003	32103	1,2-DICHLOROETHANE UG/L		1.000 <	5.000		
0000001	004	32104	BROMOFORM UG/L GC/MS		1.000 <			
0000001	005	32105	DIBROMOCHLOROMETHANE UG/L GC/MS		1.000 <			
0000001	006	32106	CHLOROFORM UG/L GC/MS		1.000 <			
0000001	007	34010	TOLUENE UG/L		1.000 <	1000.000		
0000001	008	34030	BENZENE UG/L		1.000 <	5.000		
0000001	009	34301	CHLOROBENZENE UG/L		1.000 <	100.000		
0000001	010	34371	ETHYLBENZENE UG/L		1.000 <	700.000		
0000001	011	34423	METHYLENE CHLORIDE UG/L		1.000 <	5.000		
0000001	012	34475	TETRACHLOROETHYLENE UG/L GC/MS		1.000 <	5.000		
0000001	013	34496	1,1-DICHLOROETHANE UG/L GC/MS		1.000 <			
0000001	014	34501	1,1-DICHLOROETHYLENE UG/L GC/MS		1.000 <	7.000		
0000001	015	34506	1,1,1-TRICHLOROETHANE UG/L GC/MS		1.000 <	200.000		
0000001	016	34546	TRANS-1,2-DICHLOROETHYLENE UG/L GC/MS		1.000 <	100.000		
0000001	017	39180	TRICHLOROETHYLENE UG/L		1.000 <	5.000		
0000001	018	00059	FLOW (PUMPING) RATE GAL/MIN		145.000			
0000001	019	72004	FLOW (PUMPING) TIME PRIOR TO SAMPLING MIN		385.000			
0000001	020	00410			167.000			

FACILITY: 0971500 ROUND LAKE STATUS: A PUBLIC: Y COMM: Y TYPE WATER:
TAP: 02 WELL 2 STATUS: A
RAW SRC: 20299 WELL 2 REAP 400 N CEDAR LAKE ROAD STATUS: A

SAMPLE NO: 203739 LOCATION: WELL COLL DATE: 09/06/95 DELIVERED BY:
SMPL TYPE: RAW COLLECTOR: IEPA SMPL COLLECTOR LAB RCVD: 00/00/00 RECEIVED BY:
SMPL PURP: 5-SPEC/OTHR COMMENTS: LAB COMPL: 00/00/00 LAB SUPERVISOR:
SMPL PROG: I-GWM INORG OBSRVATNS: SMPL PERIOD: 09/85 FUND CODE:

ANALYSIS ID	RSLT NO	STORET NO	DESCRIPTION	UNITS	RESULT	STANDARDS DRINK WTR	STANDARDS RAW WTR	TRIGGER LEVEL
0000001	001	00610	NITROGEN,AMMONIA TOTAL MG/L AS N		0.380			
0000001	002	00630	NITRATE & NITRITE TOTAL MG/L AS N		0.100 <	10.000		
0000001	003	00665	PHOSPHORUS, TOTAL MG/L AS P		0.010			
0000001	004	00720	CYANIDE,TOTAL MG/L AS CN		0.010 <	0.200		
0000001	005	00915	CALCIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP		28.000			
0000001	006	00927	MAGNESIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP		21.000			
0000001	007	00929	SODIUM,TOTAL RECOVERABLE MG/L AS NA ANAL BY ICP		59.000			
0000001	008	00937	POTASSIUM,TOTAL RECOVERABLE MG/L AS K ANAL BY ICP		1.400			
0000001	009	00940	CHLORIDE,TOTAL MG/L AS CL		2.400			
0000001	010	00945	SULFATE,TOTAL MG/L AS SO4		114.000			
0000001	011	00951	FLUORIDE,TOTAL MG/L AS F		1.000	4.000		

FACILITY: 0971500 ROUND LAKE *** CONTINUED ***

0000001	012	00956	SILICA,TOTAL MG/L AS SIO2	14.000			
0000001	013	01002	ARSENIC,TOTAL RECOVERABLE UG/L AS AS	1.100	<	50.000	
0000001	014	01007	BARIUM,TOTAL RECOVERABLE UG/L AS BA ANAL BY ICP	19.000		1000.000	
0000001	015	01012	BERYLLIUM,TOTAL RECOVERABLE UG/L AS BE ANAL BY ICP	0.500	<		
0000001	016	01022	BORON,TOTAL RECOVERABLE UG/L AS B ANAL BY ICP	510.000			
0000001	017	01027	CADMIUM,TOTAL RECOVERABLE UG/L AS CD ANAL BY ICP	3.000	<	10.000	
0000001	018	01034	CHROMIUM,TOTAL RECOVERABLE UG/L ASCR ANAL BY ICP	5.000	<	50.000	
0000001	019	01037	COBALT,TOTAL RECOVERABLE UG/L AS CO ANAL BY ICP	5.000	<		
0000001	020	01042	COPPER,TOTAL RECOVERABLE UG/L AS CU ANAL BY ICP	5.000	<	5000.000	
0000001	021	01045	IRON,TOTAL RECOVERABLE, UG/L AS FEANAL BY ICP	89.000		1000.000	
0000001	022	01051	LEAD,TOTAL RECOVERABLE UG/L AS PB	5.000	<	50.000	
0000001	023	01055	MANGANESE,TOTAL RECOVERABLE UG/L AS MN ANAL BY ICP	5.000	<	150.000	
0000001	024	01067	NICKEL,TOTAL RECOVERABLE UG/L AS NI ANAL BY ICP	5.000	<		
0000001	025	01077	SILVER,TOTAL RECOVERABLE UG/L AS AG ANAL BY ICP	3.000	<	50.000	
0000001	026	01082	STRONTIUM,TOTAL RECOVERABLE UG/L AS SR ANAL BY ICP	976.000			
0000001	027	01087	VANADIUM,TOTAL RECOVERABLE UG/L ASV ANAL BY ICP	5.000	<		
0000001	028	01092	ZINC,TOTAL RECOVERABLE UG/L AS ZN ANAL BY ICP	50.000	<	5000.000	
0000001	029	01105	ALUMINUM,TOTAL RECOVERABLE UG/L ASAL ANAL BY ICP	50.000	<		
0000001	030	01147	SELENIUM,TOTAL RECOVERABLE UG/L ASSE	1.000	<	10.000	
0000001	031	32730	PHENOLS, TOTAL RECOVERABLE UG/L	5.000	<		
0000001	032	70300	RESIDUE,TOTAL FILTERABLE @180 C,MG/L	390.000			
0000001	033	71900	MERCURY,TOTAL UG/L AS HG	0.010	<	2.000	
0000001	034	00010	WATER TEMPERATURE DEG C	12.500			
0000001	035	00059	FLOW (PUMPING) RATE GAL/MIN	300.000			
0000001	036	00090	OXIDATION-REDUCTION POTENTIAL (EH) MILLIVOLTS	185.000-			
0000001	037	00095	CONDUCTIVITY(EC)-LAB(UMHOS/CM @ 25 C	535.000			
0000001	038	00400	PH PH UNITS	8.000			
0000001	039	00410	ALKALINITY,TOTAL MG/L AS CACO3	176.000			
0000001	040	72004	FLOW (PUMPING) TIME PRIOR TO SAMPLING MIN	90.000			
0000001	041	72019	DEPTH FROM LAND SURFACE TO WATER SURFACE	59.000			
0000001	042	99410		171.000			

SAMPLE NO: B024842 LOCATION: WELL #2 COLL DATE: 02/09/83 DELIVERED BY:
SMPL TYPE: RAW COLLECTOR: RANDALL FIENBACH LAB RCVD: 03/15/83 RECEIVED BY:
SMPL PURP: 1-ROUTINE COMMENTS: LAB COMPL: LAB SUPERVISOR:
SMPL PROG: I-SWM INORG OBSRVATNS: SMPL PERIOD: 02/83 FUND CODE:

ANALYSIS ID	RSLT NO	STORET NO	DESCRIPTION	UNITS	RESULT		STANDARDS DRINK WTR	STANDARDS RAW WTR	TRIGGER LEVEL
		00095	CONDUCTIVITY(EC)-LAB(UMHOS/CM @ 25 C		540.000				
		00403	PH LABORATORY UNITS		8.100				
		00410	ALKALINITY,TOTAL MG/L AS CACO3		163.000				
		00610	NITROGEN,AMMONIA TOTAL MG/L AS N		0.410				
		00630	NITRATE & NITRITE TOTAL MG/L AS N		0.100	<	10.000		
		00720	CYANIDE,TOTAL MG/L AS CN		0.005	<	0.200		
		00900	HARDNESS,EDTA MG/L AS CACO3		159.000				
		00916	CALCIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP		30.000				
		00927	MAGNESIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP		20.000				
		00929	SODIUM,TOTAL RECOVERABLE MG/L AS NA ANAL BY ICP		63.000				

FACILITY: 0971500 ROUND LAKE *** CONTINUED ***

00937	POTASSIUM,TOTAL RECOVERABLE MG/L AS K ANAL BY ICP	1.500		
00940	CHLORIDE,TOTAL MG/L AS CL	1.300		
00945	SULFATE,TOTAL MG/L AS SO4	120.000		
00951	FLUORIDE,TOTAL MG/L AS F	0.890	4.000	
00956	SILICA,TOTAL MG/L AS SIO2	14.000		
01002	ARSENIC,TOTAL RECOVERABLE UG/L AS AS	1.000	50.000	
01007	BARIUM,TOTAL RECOVERABLE UG/L AS BA ANAL BY ICP	25.000	1000.000	
01012	BERYLLIUM,TOTAL RECOVERABLE UG/L AS BE ANAL BY ICP	0.500 <		
01022	BORON,TOTAL RECOVERABLE UG/L AS B ANAL BY ICP	590.000		
01027	CADMIUM,TOTAL RECOVERABLE UG/L AS CD ANAL BY ICP	3.000 <	10.000	
01034	CHROMIUM,TOTAL RECOVERABLE UG/L AS CR ANAL BY ICP	5.000 <	50.000	
01037	COBALT,TOTAL RECOVERABLE UG/L AS CO ANAL BY ICP	5.000 <		
01042	COPPER,TOTAL RECOVERABLE UG/L AS CU ANAL BY ICP	3.000 <	5000.000	
01045	IRON,TOTAL RECOVERABLE, UG/L AS FEANAL BY ICP	100.000	1000.000	
01051	LEAD,TOTAL RECOVERABLE UG/L AS PB	5.000 <	50.000	
01055	MANGANESE,TOTAL RECOVERABLE UG/L AS MN ANAL BY ICP	5.000 <	150.000	
01067	NICKEL,TOTAL RECOVERABLE UG/L AS NI ANAL BY ICP	3.000 <		
01077	SILVER,TOTAL RECOVERABLE UG/L AS AG ANAL BY ICP	5.000 <	50.000	
01082	STRONTIUM,TOTAL RECOVERABLE UG/L AS SR ANAL BY ICP	1030.000		
01087	VANADIUM,TOTAL RECOVERABLE UG/L ASV ANAL BY ICP	4.000 <		
01092	ZINC,TOTAL RECOVERABLE UG/L AS ZN ANAL BY ICP	2.000 <	5000.000	
01147	SELENIUM,TOTAL RECOVERABLE UG/L ASSE	1.000 <	10.000	
70300	RESIDUE,TOTAL FILTERABLE @180 C,MG/L	372.000		
70304	TOTAL DISSOLVED SOLIDS MG/L BY EC	320.000		
71900	MERCURY,TOTAL UG/L AS HG	0.050 <	2.000	

SAMPLE NO: Z004738 LOCATION: WELL COLL DATE: 08/06/85 DELIVERED BY:
SMPL TYPE: RAW COLLECTOR: IEPA SMPL COLLECTOR LAB RCVD: 00/00/00 RECEIVED BY:
SMPL PURP: 5-SPEC/OTHR COMMENTS: LAB COMPL: 00/00/00 LAB SUPERVISOR:
SMPL PROG: V-VOC OBSRVATNS: SMPL PERIOD: 08/85 FUND CODE:

ANALYSIS ID	RSLT NO	STORET NO	DESCRIPTION	UNITS	RESULT	STANDARDS DRINK WTR	STANDARDS RAW WTR	TRIGGER LEVEL
0000001	001	32101	BROMODICHLOROMETHANE UG/L CG/MS		1.000 <			
0000001	002	32102	CARBON TETRACHLORIDE UG/L CG/MS		1.000 <	5.000		
0000001	003	32103	1,2-DICHLOROETHANE UG/L		1.000 <	5.000		
0000001	004	32104	BROMOFORM UG/L CG/MS		1.000 <			
0000001	005	32105	DIBROMOCHLOROMETHANE UG/L GC/MS		1.000 <			
0000001	006	32106	CHLOROFORM UG/L GC/MS		1.000 <			
0000001	007	34010	TOLUENE UG/L		1.000 <	1000.000		
0000001	008	34030	BENZENE UG/L		1.000 <	5.000		
0000001	009	34301	CHLOROBENZENE UG/L		1.000 <	100.000		
0000001	010	34371	ETHYLBENZENE UG/L		1.000 <	700.000		
0000001	011	34423	METHYLENE CHLORIDE UG/L		1.000 <	5.000		
0000001	012	34475	TETRACHLOROETHYLENE UG/L GC/MS		1.000 <	5.000		
0000001	013	34496	1,1-DICHLOROETHANE UG/L GC/MS		1.000 <			
0000001	014	34501	1,1-DICHLOROETHYLENE UG/L GC/MS		1.000 <	7.000		
0000001	015	34506	1,1,1-TRICHLOROETHANE UG/L GC/MS		1.000 <	200.000		
0000001	016	34511	TRICHLOROETHYLENE UG/L		1.000 <	5.000		

REPORT: [illegible]
MODULE: [illegible]

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES
SELECTED SAMPLE EXPANDED REPORT

FACILITY: 0971500 ROUND LAKE *** CONTINUED ***

0000001	017	00010	WATER TEMPERATURE DEG C	12.500
0000001	018	00059	FLOW (PUMPING) RATE GAL/MIN	300.000
0000001	019	00090	OXIDATION-REDUCTION POTENTIAL (EH) MILLIVOLTS	135.000-
0000001	020	00095	CONDUCTIVITY(EC)-LAB(UMHOS/CM @ 25 C	535.000
0000001	021	00400	PH PH UNITS	8.000
0000001	022	00410	ALKALINITY,TOTAL MG/L AS CACO3	176.000
0000001	023	72004	FLOW (PUMPING) TIME PRIOR TO SAMPLING MIN	90.000
0000001	024	72019	DEPTH FROM LAND SURFACE TO WATER SURFACE	52.000
0000001	025	90410		171.000

FACILITY: 0971500 ROUND LAKE STATUS: A PUBLIC: Y COMM: Y TYPE WATER:
TAP: 03 WELL 3 SE FAIRFIELD NIPPERSINK RD JUNCT STATUS: A
RAW SRCE: 20300 WELL 3 1049 NIPPERSINK RD W OF FAIRFIELD STATUS: A

SAMPLE NO: Z004718 LOCATION: WELL COLL DATE: 01/07/87 DELIVERED BY:
SMPL TYPE: RAW COLLECTOR: IEPA SMPL COLLECTOR LAB RCVD: 00/00/00 RECEIVED BY:
SMPL PURP: S-SPEC/OTHR COMMENTS: LAB COMPL: 00/00/00 LAB SUPERVISOR:
SMPL PROG: I-GWM INORG OBSERVATNS: SMPL PERIOD: 01/87 FUND CODE:

ANALYSIS ID	RSLT NO	STORET NO	STORET DESCRIPTION	UNITS	RESULT		STANDARDS DRINK WTR	STANDARDS RAW WTR	TRIGGER LEVEL
0000001	001	00610	NITROGEN,AMMONIA TOTAL MG/L AS N		0.100	<			
0000001	002	00630	NITRATE & NITRITE TOTAL MG/L AS N		0.100	<	10.000		
0000001	003	00665	PHOSPHORUS, TOTAL MG/L AS P		0.010	<			
0000001	004	00720	CYANIDE,TOTAL MG/L AS CN		0.010	<	0.200		
0000001	005	00916	CALCIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP		56.000				
0000001	006	00927	MAGNESIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP		19.000				
0000001	007	00929	SODIUM,TOTAL RECOVERABLE MG/L AS NA ANAL BY ICP		20.000				
0000001	008	00937	POTASSIUM,TOTAL RECOVERABLE MG/L AS K ANAL BY ICP		5.600				
0000001	009	00940	CHLORIDE,TOTAL MG/L AS CL		6.500				
0000001	010	00945	SULFATE,TOTAL MG/L AS SO4		11.000				
0000001	011	00951	FLUORIDE,TOTAL MG/L AS F		0.950		4.000		
0000001	012	00955	SILICA,TOTAL MG/L AS SIO2		7.300				
0000001	013	00956	SILICA,TOTAL MG/L AS SIO2		7.300				
0000001	014	01002	ARSENIC,TOTAR RECOVERABLE UG/L AS AS		1.000	<	50.000		
0000001	015	01007	BARIUM,TOTAL RECOVERABLE UG/L AS BA ANAL BY ICP		1050.000		1000.000		
0000001	016	01012	BERYLLIUM,TOTAL RECOVERABLE UG/L AS BE ANAL BY ICP		0.500	<			
0000001	017	01022	BORON,TOTAL RECOVERABLE UG/L AS B ANAL BY ICP		135.000				
0000001	018	01027	CADMIUM,TOTAL RECOVERABLE UG/L AS CD ANAL BY ICP		3.000	<	10.000		
0000001	019	01034	CHROMIUM,TOTAL RECOVERABLE UG/L ASCR ANAL BY ICB		5.000	<	50.000		
0000001	020	01037	COBALT,TOTAL RECOVERABLE UG/L AS CO ANAL BY ICP		5.000	<			
0000001	021	01042	COPPER,TOTAL RECOVERABLE UG/L AS CU ANAL BY ICP		5.000	<	5000.000		
0000001	022	01045	IRON,TOTAL RECOVERABLE, UG/L AS FEANAL BY ICP		206.000		1000.000		
0000001	023	01051	LEAD,TOTAL RECOVERABLE UG/L AS PB		5.000	<	50.000		
0000001	024	01055	MANGANESE,TOTAL RECOVERABLE UG/L AS MN ANAL BY ICP		5.000	<	150.000		
0000001	025	01067	NICKEL,TOTAL RECOVERABLE UG/L AS NI ANAL BY ICP		3.000	<			
0000001	026	01077	SILVER,TOTAL RECOVERABLE UG/L AS AG ANAL BY ICP		3.000	<	50.000		
0000001	027	01082	STRONTIUM,TOTAL RECOVERABLE UG/L AS SR ANAL BY ICP		5352.000				
0000001	028	01087	VANADIUM,TOTAL RECOVERABLE UG/L ASV ANAL BY ICP		5.000	<			

FACILITY: 0771900 ROUND LAKE *** CONTINUED ***

0000001	029	01092	ZINC,TOTAL RECOVERABLE UG/L AS ZN ANAL BY ICP	50.000 <	5000.000
0000001	030	01105	ALUMINUM,TOTAL RECOVERABLE UG/L ASAL ANAL BY ICP	50.000 <	
0000001	031	01147	SELENIUM,TOTAL RECOVERABLE UG/L ASSE	1.000 <	10.000
0000001	032	32730	PHENOLS, TOTAL RECOVERABLE UG/L	5.000 <	
0000001	033	70300	RESIDUE,TOTAL FILTERABLE @180 C,MG/L	375.000	
0000001	034	71900	MERCURY,TOTAL UG/L AS HG	0.050 <	2.000
0000001	035	00010	WATER TEMPERATURE DEG C	15.500	
0000001	036	00059	FLOW (PUMPING) RATE GAL/MIN	450.000	
0000001	037	00090	OXIDATION-REDUCTION POTENTIAL (EH) MILLIVOLTS	88.000-	
0000001	038	00095	CONDUCTIVITY(EC)-LAB(UMHOS/CM @ 25 C	515.000	
0000001	039	00400	PH PH UNITS	7.400	
0000001	040	72004	FLOW (PUMPING) TIME PRIOR TO SAMPLING MIN	60.000	
0000001	041	90410		259.000	

SAMPLE NO: 8002237 LOCATION: WELL #3 COLL DATE: 07/19/82 DELIVERED BY:
SMPL TYPE: RAW COLLECTOR: RANDALL FIENBACH LAB RCVD: 07/20/82 RECEIVED BY:
SMPL PURP: 1-ROUTINE COMMENTS: LAB COMPL: LAB SUPERVISOR:
SMPL PROG: I-041 INORG OBSRVATNS: SMPL PERIOD: 07/82 FUND CODE:

ANALYSIS ID	RSLT NO	STORET NO	DESCRIPTION	UNITS	RESULT	STANDARDS DRINK WTR	STANDARDS RAW WTR	TRIGGER LEVEL
		00095	CONDUCTIVITY(EC)-LAB(UMHOS/CM @ 25 C		520.000			
		00403	PH LABORATORY UNITS		7.300			
		00410	ALKALINITY,TOTAL MG/L AS CACO3		270.000			
		00610	NITROGEN,AMMONIA TOTAL MG/L AS N		0.190			
		00630	NITRATE & NITRITE TOTAL MG/L AS N		0.100 <	10.000		
		00720	CYANIDE,TOTAL MG/L AS CN		0.005 <	0.200		
		00900	HARDNESS,EDTA MG/L AS CACO3		219.000			
		00916	CALCIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP		59.000			
		00927	MAGNESIUM,TOTAL RECOVERABLE MG/L AS CA ANAL BY ICP		19.000			
		00929	SODIUM,TOTAL RECOVERABLE MG/L AS NA ANAL BY ICP		21.000			
		00937	POTASSIUM,TOTAL RECOVERABLE MG/L AS K ANAL BY ICP		11.000			
		00940	CHLORIDE,TOTAL MG/L AS CL		6.500			
		00945	SULFATE,TOTAL MG/L AS SO4		18.000			
		00951	FLUORIDE,TOTAL MG/L AS F		0.970	4.000		
		00956	SILICA,TOTAL MG/L AS SIO2		7.000			
		01002	ARSENIC,TOTAL RECOVERABLE UG/L AS AS		1.000 <	50.000		
		01007	BARIUM,TOTAL RECOVERABLE UG/L AS BA ANAL BY ICP		1000.000	1000.000		
		01012	BERYLLIUM,TOTAL RECOVERABLE UG/L AS BE ANAL BY ICP		0.500 <			
		01022	BORON,TOTAL RECOVERABLE UG/L AS B ANAL BY ICP		150.000			
		01027	CADMIUM,TOTAL RECOVERABLE UG/L AS CD ANAL BY ICP		3.000 <	10.000		
		01034	CHROMIUM,TOTAL RECOVERABLE UG/L ASCR ANAL BY ICP		5.000 <	50.000		
		01037	COBALT,TOTAL RECOVERABLE UG/L AS CO ANAL BY ICP		5.000 <			
		01042	COPPER,TOTAL RECOVERABLE UG/L AS CU ANAL BY ICP		6.000	5000.000		
		01045	IRON,TOTAL RECOVERABLE, UG/L AS FEANAL BY ICP		220.000	1000.000		
		01051	LEAD,TOTAL RECOVERABLE UG/L AS PB		5.000 <	50.000		
		01055	MANGANESE,TOTAL RECOVERABLE UG/L AS MN ANAL BY ICP		5.000 <	150.000		
		01067	NICKEL,TOTAL RECOVERABLE UG/L AS NI ANAL BY ICP		3.000 <			
		01077	SILVER,TOTAL RECOVERABLE UG/L AS AG ANAL BY ICP		5.000 <	50.000		

FACILITY: 0971500 ROUND LAKE *** CONTINUED ***

STORET	DESCRIPTION	RESULT		DRINK WTR
01082	STRONTIUM,TOTAL RECOVERABLE UG/L AS SR ANAL BY ICP	5860.000		
01087	VANADIUM,TOTAL RECOVERABLE UG/L ASV ANAL BY ICP	4.000	<	
01092	ZINC,TOTAL RECOVERABLE UG/L AS ZN ANAL BY ICP	2.000	<	5000.000
01147	SELENIUM,TOTAL RECOVERABLE UG/L ASSE	1.000	<	10.000
70300	RESIDUE,TOTAL FILTERABLE @180 C,MG/L	270.000		
70304	TOTAL DISSOLVED SOLIDS MG/L BY EC	310.000		
71900	MERCURY,TOTAL UG/L AS HG	0.050	<	2.000

SAMPLE NO: 2004717 LOCATION: WELL COLL DATE: 01/07/87 DELIVERED BY:
SMPL TYPE: RAW COLLECTOR: IEPA SMPL COLLECTOR LAB RCVD: 00/00/00 RECEIVED BY:
SMPL PURP: 5-SPEC/OTHR COMMENTS: LAB COMPL: 00/00/00 LAB SUPERVISOR:
SMPL PROJ: V-VOC OBSRVATNS: SMPL PERIOD: 01/87 FUND CODE:

ANALYSIS ID	RSLT NO	STORET NO	DESCRIPTION	UNITS	RESULT		STANDARDS DRINK WTR	STANDARDS RAW WTR	TRIGGER LEVEL
0000001	001	32101	BROMODICHLOROMETHANE UG/L CG/MS		1.000	<			
0000001	002	32102	CARBON TETRACHLORIDE UG/L CG/MS		1.000	<	5.000		
0000001	003	32103	1,2-DICHLOROETHANE UG/L		1.000	<	5.000		
0000001	004	32104	BROMOFORM UG/L CG/MS		1.000	<			
0000001	005	32105	DIBROMOCHLOROMETHANE UG/L GC/MS		1.000	<			
0000001	006	32106	CHLOROFORM UG/L GC/MS		1.000	<			
0000001	007	34010	TOLUENE UG/L		1.000	<	1000.000		
0000001	008	34030	BENZENE UG/L		1.000	<	5.000		
0000001	009	34301	CHLOROBENZENE UG/L		1.000	<	100.000		
0000001	010	34371	ETHYLBENZENE UG/L		1.000	<	700.000		
0000001	011	34423	METHYLENE CHLORIDE UG/L		1.000	<	5.000		
0000001	012	34475	TETRACHLOROETHYLENE UG/L GC/MS		1.000	<	5.000		
0000001	013	34496	1,1-DICHLOROETHANE UG/L GC/MS		1.000	<			
0000001	014	34501	1,1-DICHLOROETHYLENE UG/L GC/MS		1.000	<	7.000		
0000001	015	34506	1,1,1-TRICHLOROETHANE UG/L GC/MS		1.000	<	200.000		
0000001	016	34546	TRANS-1,2-DICHLOROETHYLENE UG/L GC/MS		1.000	<	100.000		
0000001	017	39180	TRICHLOROETHYLENE UG/L		1.000	<	5.000		
0000001	018	00010	WATER TEMPERATURE DEG C		15.500				
0000001	019	00059	FLOW (PUMPING) RATE GAL/MIN		450.000				
0000001	020	00090	OXIDATION-REDUCTION POTENTIAL (EH) MILLIVOLTS		88.000-				
0000001	021	00095	CONDUCTIVITY(EC)-LAB(UMHOS/CM @ 25 C		515.000				
0000001	022	00400	PH PH UNITS		7.400				
0000001	023	72004	FLOW (PUMPING) TIME PRIOR TO SAMPLING MIN		60.000				
0000001	024	[illegible]			259.000				

ROUND LAKE

The village of Round Lake (1531) installed a public water supply in 1914. One well (No. 2) is in use and another well (No. 1) is available for emergency use. This supply was cross connected with Round Lake Park in October 1951, but water from Round Lake Park has not been used for several years. In 1949 there were 140 services, all metered; the average and maximum daily pumpages were 50,000 and 75,000 gpd, respectively. In 1973 there were 500 services, all metered; the average and maximum daily pumpages were 190,000 and 280,000 gpd, respectively. The water is chlorinated. The natural fluoride concentration in the water is adequate to satisfy state requirements.

WELL NO. 1, finished in Silurian dolomite, was completed in 1912 to a depth of 350 ft by Adam Titus, Libertyville. This well is available for emergency use. The well is located in the rear of the village hall, about 110 ft south of the Chicago, Milwaukee, and St. Paul RR and 430 ft east of Cedar Lake Road, approximately 1550 ft S and 2400 ft W of the NE corner of Section 29, T45N, R10E. The land surface elevation at the well is approximately 798 ft.

A 6-in. diameter hole was drilled to a depth of 350 ft. The well is cased with 6-in. pipe from land surface to a depth of 230 ft.

Upon completion, water was pumped at a rate of 150 gpm for 24 hr. The water returned to its original level soon after the pump was stopped. In the summer of 1922 when the pump was pulled, the depth to water was 43 ft below the pump base.

In January 1945, the well reportedly produced 175 gpm for 1.5 hr with a drawdown of 10 ft from a nonpumping water level of 40 ft below the pump base.

The pumping equipment presently installed consists of a 10-hp 1750 rpm General Electric Induction motor (No. 5345661), a 6-in., 16-stage Cook turbine pump (Serial No. 1912) set at 150 ft, rated at 130 gpm, and has 150 ft of 4-in. OD column pipe. The well is equipped with 150 ft of airline without a gage.

A mineral analysis of a sample (Lab. No. 107669) collected September 10, 1946, after pumping for 4 hr at 125 gpm, showed the water to have a hardness of 165 mg/l, total dissolved minerals of 434 mg/l, and an iron content of 0.1 mg/l.

WELL NO. 2, finished in Silurian dolomite, was completed in May 1945 to a depth of 359 ft by Henry Boysen, Jr., Libertyville, and filled in to a 333-ft depth by the Aurora Pump Co. during the summer of 1963. The well is located in the rear of the village garage, about 360 ft north of the main track of the Chicago, Milwaukee, and St. Paul RR and 80 ft west of the center line of Cedar Lake Road, approximately 600 ft S and 2175 ft E of the NW corner of Section 29, T45N, R10E. The land surface elevation at the well is approximately 790 ft.

A sample study log of Well No. 2 furnished by the State Geological Survey follows:

Strata	*Thickness (ft)*	*Depth (ft)*
PLEISTOCENE SYSTEM		
Clay, glacial till and silt	169	169
Sand and gravel	2	171
Sand, silty	44	215
Sand and gravel	10	225
SILURIAN SYSTEM		
Niagaran–Alexandrian Series		
Dolomite	89	314
ORDOVICIAN SYSTEM		
Maquoketa Group		
Dolomite, shale at top and base	45	359

A 10-in. diameter hole was drilled to a depth of 359 ft. The well is cased with 10-in. ID pipe from 2 ft above land surface to a depth of 226 ft.

A production test was conducted on May 19, 1945. The well reportedly produced from 280 to 295 gpm for 7.6 hr with a drawdown of 107 ft from a nonpumping water level of 51 ft below the top of the casing. Ten min after pumping was stopped, the water level had recovered to 56 ft.

In June 1963, this well was rejuvenated by the Aurora Pump Co. and the nonpumping water level was reported to be 85 ft above the bottom of the column pipe.

The pumping equipment presently installed is an 8-in., 10-stage Aurora turbine pump (Type DWT) set at 140 ft, rated at 250 gpm at about 275 ft TDH, and powered by a 25-hp 1800 rpm U.S. electric motor (Serial No. 586755). A 10-ft section of 6-in. suction pipe is attached to the pump intake. The well is equipped with 140 ft of airline.

The following mineral analysis made by the Illinois Environmental Protection Agency (Lab. No. C005278) is for a water sample from the well collected January 22, 1974, after 1 hr of pumping at 325 gpm.

WELL NO. 2, LABORATORY NO. C005278

		mg/l	*me/l*			*mg/l*	*me/l*
Iron	Fe	0.1		Silica	SiO_2	14.0	
Manganese	Mn	0.00		Fluoride	F	0.9	0.05
Ammonium	NH_4	0.77	0.04	Boron	B	0.7	
Sodium	Na	60	2.61	Nitrate	NO_3	0.3	0.00
Potassium	K	1.3	0.03	Chloride	Cl	3	0.08
Calcium	Ca	28	1.40	Sulfate	SO_4	122	2.54
Magnesium	Mg	18	1.48	Alkalinity (as $CaCO_3$)		158	3.16
Arsenic	As	0.00					
Barium	Ba	0.0		Hardness (as $CaCO_3$)		144	2.88
Copper	Cu	0.00					
Cadmium	Cd	0.00		Total dissolved minerals		326	
Chromium	Cr	0.00					
Lead	Pb	0.00					
Mercury	Hg	0.0000		pH (as rec'd)		8.2	
Nickel	Ni	0.0		Radioactivity			
Selenium	Se	0.00		Alpha *pc/l*		0.1	
Silver	Ag	0.00		±deviation		0.8	
Cyanide	CN	0.00		Beta *pc/l*		1.7	
Zinc	Zn	0.01		±deviation		1.6	

WELL NO. 3, open to the Cambrian–Ordovician aquifer, was completed in August 1974 to a depth of 1241 ft by the Hoover Water Well Service, Zion. As of March 1976, this well was not in use. The well is located on Nippersink Road, approximately 2600 ft N and 1575 ft W of the SE corner of Section 30, T45N, R10E. The land surface elevation at the well is approximately 790 ft.

A drillers log of Well No. 3 follows:

Strata	*Thickness (ft)*	*Depth (ft)*
Glacial drift	196	196
Silurian dolomite	169	365
Maquoketa shale	127	492
Galena-Platteville dolomite	248	740
Glenwood	114	854
St. Peter sandstone	104	958
Trempealeau	144	1102
Gelesville sandstone	126	1228
Shale	13	1241

A 12-in. diameter hole was drilled to a depth of 588 ft, reduced to 10 in. between 588 and 1027 ft, and finished 8 in. in diameter from 1027 to 1241 ft. The well is cased with 12-in. pipe from land surface to a depth of 193 ft, 10-in. pipe from land surface to a depth of 588 ft (cemented in), and an 8-in. liner from 759 ft to a depth of 1027 ft (slotted between 860 and 950 ft).

A production test was conducted by the driller on August 19-20, 1974. After 24.2 hr of pumping at a rate of 300 gpm, the final drawdown was 120 ft from a nonpumping water level of 377 ft.

The pumping equipment presently installed is a Johnston vertical turbine pump set at 660 ft, rated at 450 gpm at about 690 ft TDH, and powered by a 125-hp 1770 rpm electric motor.

A partial analysis of a sample (Lab. No. 196669) collected during the initial production test, showed the water to have a hardness of 232 mg/l, total dissolved minerals of 319 mg/l, and an iron content of 0.5 mg/l.

APPENDIX G

HAZARD REVIEW WORKSHEET

1. Unique I.D. Number 2 0 2 9 8 - 0 1 - _ _ , Distance and Direction from the Wellhead 100 ft. southwest of the well

2. Nature of Business Hardware Store

3. DLPC Permit Number(s) and Description (e.g., RCRA, Generic, Solid Waste, UIC, etc.): None

4. DAPC Permit Number(s) and Description: None

5. DWPC Permit Numbers and Description (e.g., NPDES, Industrial Pre-Treatment, Sewer Plans, etc.): None

6. ERU Incidents and Description: None

7. ERU 313 Reports and Description: None

8. ESDA 302/303 Reports and Description: None

9. ESDA 311/312 Reports and Description: None

10. PWS compliance monitoring conducted and describe the results (e.g., VOC/VOA sample detects, etc.): None

11. ISFM list the underground storage tanks registered, provide the owner name & address:

Owner Name	Address

12. Is the site sewered or non-sewered? Sewered

    If the site is not sewered, describe: _____

13. Has on-site past or present landfilling, land treating, or surface impoundment of waste, other than landscape waste or construction and demolition debris occured?

    ( ) Yes. If yes, describe: _____

    (X) No.

14. Are there currently any on-site piles of special or hazardous waste?

    ( ) Yes. If yes, describe: _____

    (X) No.

15. Are on-site piles of waste (other than special or hazardous wastes) managed according to Agency guidelines?

    ( ) Yes. If yes, describe: _____

    (X) No.

16. Are there currently any underground storage tanks present on-site, and will any underground tanks be installed in the future?

    ( ) Yes. If yes, describe: _____

    (X) No.

17(a). Has any situation(s) occurred at this site which resulted in a "release" of any hazardous substance or petroleum?

    ( ) Yes (continue to next question)
    (X) No (stop here)

(b). Have any hazardous substances or petroleum, which were released, come into contact with the ground surface at this site? (Note--do not automatically exclude paved or otherwise covered areas that may still have allowed chemical substances to penetrate into the ground.)

    ( ) Yes (continue to next question)
    ( ) No (stop here)

(c). Have any of the following actions/events been associated with the release(s) referred to in question 17(b)?

    ( ) Hiring of a cleanup contractor to remove obviously contaminated materials including subsoils

    ( ) Replacement or major repair of damaged facilities

(c).(continued)

( ) Assignment of in-house maintenance staff to remove obviously contaminated materials including subsoils

( ) Designation, by IEPA or the ESDA, of a release as "significant" under the Illinois Chemical Safety Act

( ) Reordering or other replenishment of inventory due to the amount of substance lost

( ) Temporary or more long-term monitoring of groundwater at or near the site

( ) Stop usage of an on-site or nearby water well because of offensive characteristics of the water

( ) Coping with fumes from subsurface storm drains or inside basements

( ) Signs of substances leaching out of the ground along the base of slopes or at other low points on or adjacent to the site

(d). The on-site release(s) may have been of sufficient magnitude to contaminate groundwaters. Summarize the problem.

_____
_____
_____
_____
_____

18. Are there more than 100 gallons of either pesticides or organic solvents, or 10,000 gallons of any hazardous substance, or 30,000 gallons of petroleum present at any time?

( ) Yes. If yes, describe: _____
_____

(X) No.

19. Do any of the regulated entities have groundwater monitoring systems, and have any exceeded compliance requirements?

( ) Yes. If yes, describe: _____
_____

(X) No.

20. After considering all of the above criteria does this site potentially pose a hazard to groundwater?

( ) Yes. If yes, describe: _____
_____
_____
_____
_____

(X) No.

HAZARD REVIEW WORKSHEET

1. Unique I.D. Number 2 0 2 9 8 - 0 3 - P S , Distance and Direction from the Wellhead 100 ft. northwest of the well

2. Nature of Business Service Station and [illegible]

3. DLPC Permit Number(s) and Description (e.g., RCRA, Generic, Solid Waste, UIC, etc.): None

4. DAPC Permit Number(s) and Description: None

5. DWPC Permit Numbers and Description (e.g., NPDES, Industrial Pre-Treatment, Sewer Plans, etc.): None

6. ERU Incidents and Description: None

7. ERU 313 Reports and Description: None

8. ESDA 302/303 Reports and Description: None

9. ESDA 311/312 Reports and Description: None

10. PWS compliance monitoring conducted and describe the results (e.g., VOC/VOA sample detects, etc.): None

11. ISFM list the underground storage tanks registered, provide the owner name & address:

Owner Name	Address
Gerald Molidor	320 W. Nippersink, Round Lake, IL 60073

12. Is the site sewered or non-sewered? Sewered

If the site is not sewered, describe: _____

13. Has on-site past or present landfilling, land treating, or surface impoundment of waste, other than landscape waste or construction and demolition debris occured?

( ) Yes. If yes, describe: _____

(X) No.

14. Are there currently any on-site piles of special or hazardous waste?

( ) Yes. If yes, describe: _____

(X) No.

15. Are on-site piles of waste (other than special or hazardous wastes) managed according to Agency guidelines?

( ) Yes. If yes, describe: _____

(X) No.

16. Are there currently any underground storage tanks present on-site, and will any underground tanks be installed in the future?

(X) Yes. If yes, describe: 3 registered underground storage tanks on site. OSFM #2-018131

( ) No.

17(a). Has any situation(s) occurred at this site which resulted in a "release" of any hazardous substance or petroleum?

( ) Yes (continue to next question)
(X) No (stop here)

(b). Have any hazardous substances or petroleum, which were released, come into contact with the ground surface at this site? (Note--do not automatically exclude paved or otherwise covered areas that may still have allowed chemical substances to penetrate into the ground.)

( ) Yes (continue to next question)
( ) No (stop here)

(c). Have any of the following actions/events been associated with the release(s) referred to in question 17(b)?

( ) Hiring of a cleanup contractor to remove obviously contaminated materials including subsoils

( ) Replacement or major repair of damaged facilities

(c).(continued)

( ) Assignment of in-house maintenance staff to remove obviously contaminated materials including subsoils

( ) Designation, by IEPA or the ESDA, of a release as "significant" under the Illinois Chemical Safety Act

( ) Reordering or other replenishment of inventory due to the amount of substance lost

( ) Temporary or more long-term monitoring of groundwater at or near the site

( ) Stop usage of an on-site or nearby water well because of offensive characteristics of the water

( ) Coping with fumes from subsurface storm drains or inside basements

( ) Signs of substances leaching out of the ground along the base of slopes or at other low points on or adjacent to the site

(d). The on-site release(s) may have been of sufficient magnitude to contaminate groundwaters. Summarize the problem.

_____
_____
_____
_____
_____
_____

18. Are there more than 100 gallons of either pesticides or organic solvents, or 10,000 gallons of any hazardous substance, or 30,000 gallons of petroleum present at any time?

( ) Yes. If yes, describe: _____
_____

(X) No.

19. Do any of the regulated entities have groundwater monitoring systems, and have any exceeded compliance requirements?

( ) Yes. If yes, describe: _____
_____

(X) No.

20. After considering all of the above criteria does this site potentially pose a hazard to groundwater?

(X) Yes. If yes, describe: Any below ground fuel tanks in close proximity to a water well is a potential hazard to groundwater.

( ) No.

HAZARD REVIEW WORKSHEET

1. Unique I.D. Number 2 0 2 9 8 - 0 4 - _ _ , Distance and Direction from the Wellhead 50 ft. north of the well

2. Nature of Business Lumber Yard

3. DLPC Permit Number(s) and Description (e.g., RCRA, Generic, Solid Waste, UIC, etc.): None

4. DAPC Permit Number(s) and Description: None

5. DWPC Permit Numbers and Description (e.g., NPDES, Industrial Pre-Treatment, Sewer Plans, etc.): None

6. ERU Incidents and Description: None

7. ERU 313 Reports and Description: None

8. ESDA 302/303 Reports and Description: None

9. ESDA 311/312 Reports and Description: None

10. PWS compliance monitoring conducted and describe the results (e.g., VOC/VOA sample detects, etc.): None

11. ISFM list the underground storage tanks registered, provide the owner name & address:

Owner Name	Address

12. Is the site sewered or non-sewered? Sewered

    If the site is not sewered, describe: _____

13. Has on-site past or present landfilling, land treating, or surface impoundment of waste, other than landscape waste or construction and demolition debris occured?

    ( ) Yes. If yes, describe: _____

    (X) No.

14. Are there currently any on-site piles of special or hazardous waste?

    ( ) Yes. If yes, describe: _____

    (X) No.

15. Are on-site piles of waste (other than special or hazardous wastes) managed according to Agency guidelines?

    ( ) Yes. If yes, describe: _____

    (X) No.

16. Are there currently any underground storage tanks present on-site, and will any underground tanks be installed in the future?

    ( ) Yes. If yes, describe: _____

    (X) No.

17(a). Has any situation(s) occurred at this site which resulted in a "release" of any hazardous substance or petroleum?

    ( ) Yes (continue to next question)
    (X) No (stop here)

(b). Have any hazardous substances or petroleum, which were released, come into contact with the ground surface at this site? (Note--do not automatically exclude paved or otherwise covered areas that may still have allowed chemical substances to penetrate into the ground.)

    ( ) Yes (continue to next question)
    ( ) No (stop here)

(c). Have any of the following actions/events been associated with the release(s) referred to in question 17(b)?

    ( ) Hiring of a cleanup contractor to remove obviously contaminated materials including subsoils

    ( ) Replacement or major repair of damaged facilities

(c).(continued

( ) Assignment of in-house maintenance staff to remove obviously contaminated materials including subsoils

( ) Designation, by IEPA or the ESDA, of a release as "significant" under the Illinois Chemical Safety Act

( ) Reordering or other replenishment of inventory due to the amount of substance lost

( ) Temporary or more long-term monitoring of groundwater at or near the site

( ) Stop usage of an on-site or nearby water well because of offensive characteristics of the water

( ) Coping with fumes from subsurface storm drains or inside basements

( ) Signs of substances leaching out of the ground along the base of slopes or at other low points on or adjacent to the site

(d). The on-site release(s) may have been of sufficient magnitude to contaminate groundwaters. Summarize the problem.

_____
_____
_____
_____
_____

18. Are there more than 100 gallons of either pesticides or organic solvents, or 10,000 gallons of any hazardous substance, or 30,000 gallons of petroleum present at any time?

( ) Yes. If yes, describe: _____
_____

(x) No.

19. Do any of the regulated entities have groundwater monitoring systems, and have any exceeded compliance requirements?

( ) Yes. If yes, describe: _____
_____

(x) No.

20. After considering all of the above criteria does this site potentially pose a hazard to groundwater?

( ) Yes. If yes, describe: _____
_____
_____
_____
_____

(x) No.